

Coffs Harbour Drinking Water Quality Report – May 2024

Results for the 12 months from 1st May 2023 to 31st May 2024 from the NSW Health Drinking Water Monitoring Program

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Chemistry	Aluminium	0.2000	mg/L	0.0167	0.0100	0.0089	0.01	0.03	12	0	0.03	0.01	100.00
	Copper	2.0000	mg/L	0.0101	0.0060	0.0076	0.001	0.022	12	0	0.022	0.001	100.00
	Fluoride	1.5000	mg/L	0.9925	0.9900	0.0357	0.92	1.04	12	0	1.04	0.92	100.00
	Iron	0.3000	mg/L	0.0063	0.0050	0.0023	0.005	0.01	12	0	0.01	0.005	100.00
	Lead	0.0100	mg/L	0.0001	0.0001	0.0001	0.0001	0.0004	12	0	0.0004	0.0001	100.00
	Manganese	0.5000	mg/L	0.0020	0.0016	0.0012	0.0004	0.0039	12	0	0.0039	0.0004	100.00
	pH	6.5 - 8.5		7.5417	7.5500	0.1621	7.2	7.8	12	0	7.8	7.2	100.00
	Total Dissolved Solids (TDS)	10000.0000	mg/L	84.0000	74.5000	31.0601	65	181	12	0	181	65	100.00
	Total Hardness as CaCO ₃	200.0000	mg/L	52.9833	52.8000	3.6971	46.5	59.1	12	0	59.1	46.5	100.00

	True Colour	15.0000	Hazen Units (HU)	0.8750	1.0000	0.4330	0.5	2	12	0	2	0.5	100.00
	Turbidity	5.0000	NTU	0.2125	0.1500	0.1680	0.05	0.6	12	0	0.6	0.05	100.00
Microbiology													
	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	625	0	0	0	100.00
	Turbidity	5.0000	NTU	0.1516	0.0800	0.7413	0	17.9	625	1	0.34	0.02	99.84
Coffs Harbour Laboratory	Alkalinity (May 2024)			42.7			39.7	45.2	4				



Published by City of Coffs Harbour

12/06/2024